

COUNCIL COMMUNICATION


TO: THE CITY COUNCIL	COUNCIL MEETING DATE	NO.
FROM: THE CITY MANAGER'S OFFICE	JULY 11, 1990	
SUBJECT: SPECIFICATIONS FOR PURCHASE OF WATTHOUR METERS		

RECOMMENDED ACTION: That the City Council approve the specifications and authorize the advertisement for bids for the purchase of 672 watt-hour meters.

BACKGROUND INFORMATION: The Electric Utility Department has requested that 672 single-phase watthour meters be purchased to maintain an inventory for installation of meters at new developments, and for replacement of obsolete and deteriorated meters located during meter testing.

The estimated cost of this purchase is \$22,500, with funding available in the Electric Utility Department's operating fund.

The bid opening has been scheduled for Tuesday, July 31, 1990.


Joel E. Harris
Purchasing Officer

cc: Electric Utility Director
Assistant Electric Utility Director
Electrical Engineer

EQUIPMENT SPECIFICATIONS

WATTHOUR METERS

1.3 GENERAL

Meter shall be single-phase watthour with clock dial register, self-contained socket-type having a "Lexan" cover. A label marked "City of Lodi" and a sequential number beginning with 31936 shall be factory installed on each meter. Shipping boxes shall show on the outside the sequential number of the meters contained within.

1.4 RATING

Form 2S, 4 terminal, 240 volt, 3 wire, Class 200, 5 dials, Kh 7.2, Test Amp 30, multiplying factor 1.